VISC¢







/49

### **Model Number**

## RL28-54-G-Z/49/116

շ**(Սլ)**սs

Retroreflective sensor with terminal compartment

# **Features**

CE

- Detects transparent objects, i.e., clear ٠ glass, PET and transparent films
- TEACH-IN switch for setting the • contrast detection levels
- Automatic adjustment in case of • soiling in contrast detection mode
- Ultra bright LEDs for power on, weak ٠ signal indication and switching state
- Flashing power on LED in case of • short-circuit
- Not sensitive to ambient light, even • with energy saving lamps
- Impulsed time element off-delay ٠
- Waterproof, degree of protection IP67 •
- Protection class II •

### **Electrical connection**



O = Light on = Dark on

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Technical data			Accessories
General specifications			ОМН-05
Effective detection range		0 5.6 m	Mounting aid for round steel ø 12 mm or
Reflector distance		0 5.6 m	sheet 1.5 mm 3 mm
Threshold detection range		7 m	ОМН-07
Reference target		H85-2 reflector	
Light source		LED	Mounting aid for round steel ø 12 mm or
Light type		modulated visible red light , 660 nm	sheet 1.5 mm 3 mm
Polarization filter		yes	OMH-21
Diameter of the light spot		approx. 90 mm at a distance of 5.6 m	Mounting bracket
Angle of divergence		Emitter: 1 ° Receiver: 1.2 °	incurring bracitor
Ambient light limit		50000 Lux	OMH-22
Functional safety related par	rameters		Mounting bracket
MTTF <sub>d</sub>		1020 a	
Mission Time (T <sub>M</sub> )		20 a	OMH-MLV11-K
Diagnostic Coverage (DC)		0 %	dove tail mounting clamp
Indicators/operating means			OMH-RLK29
Operation indicator		LED green, flashes in case of short-circuit	Mounting bracket
Function indicator		2 LEDs yellow for switching state, stability control, TEACH-IN	Mounting bracket
Control alamanta		and contrast detection mode rotary switch for light/dark, 5-step switch for contrast recognition	OMH-RLK29-HW
Control elements		adjustment	Mounting bracket for rear wall mounting
Contrast detection levels		10 % - clean, water filled PET bottles	OMH-RL28-C
		18 % - clear glass bottles	
		40 % - colored glass or opaque materials adjustable by Teach-In key or external wire	Weld slag cover model
Electrical specifications			Other suitable accessories can be found at
Operating voltage	UB	10 30 V DC	www.pepperl-fuchs.com
Ripple	OB	10 %	
No-load supply current	I <sub>0</sub>	≤ 50 mA	
Input	-0		
Function input		Ext. Teach-In input (ET)	
Output			
Switching type		light/dark on switchable	
Signal output		1 NPN, 1 PNP synchronized-switching, short-circuit protected,	
olghal output		reverse polarity protected , open collectors	
Switching voltage		max. 30 V DC	
Switching current		max. 200 mA	
Voltage drop	U <sub>d</sub>	≤ 2.5 V DC	
Switching frequency	f	1000 Hz	
Response time		0.5 ms	
Timer function		Impulsed time element off-delay 20 ms	
Conformity			
Product standard		EN 60947-5-2	
Ambient conditions			
Ambient temperature		-40 60 °C (-40 140 °F)	
Storage temperature		-40 75 °C (-40 167 °F)	
Mechanical specifications			
Housing width		25.8 mm	
Housing height		88 mm	
Housing depth		65.5 mm	
Degree of protection		IP67	
Connection		terminal compartment with 8 spring-loaded terminals for wire cross section 0.5 1.5 mm <sup>2</sup> , insulation stripping 7.5 8.5 mm, M16 x 1.5 cable gland	
Material			
Housing		Plastic ABS	
Optical face		Plastic pane	
Mass		90 g	
Approvals and certificates			
Protection class		II, rated voltage $\leq$ 250 V AC with pollution degree 1-2	
		according to IEC 60664-1 Caution! The protection class 2 is only valid when the terminal compartment is closed.	
UL approval		cULus	
CCC approval		CCC approval / marking not required for products rated ≤36 V	
οσο αρφιοναι		COC approvary marking not required for products rated 536 V	

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" Pepperl+Fuchs Group USA: +1 330 486 0001

www.pepperl-fuchs.com

2

Germany: +49 621 776 4411

fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com PEPPERL+FUCHS

### **Curves/Diagrams**





## **TEACH-IN**

· Switch position "N" (standard operation):

LEDs are lit when the light beam is unobstructed, they flash when the value falls short of the function reserve and they go out when the beam is interrupted.

- Switch position "T" (Teach-in mode):
- After 1 s, the LED flashes slowly (approx. 1.5 Hz). The sensor is now ready to be set for a specific contrast detection value either via the mechanical switch (pos. I, II or III) or an external signal.
- Switch positions "I", "II" and "III" (contrast detection mode)
- Contrast recognition values: I for 10 %, II for 18 %, III for 40 %
- 1. LED permanently lit: light path unobstructed
- 2. LED off: element to be sensed detected
- 3. LED flashes rapidly: detection failure, excessive soiling, function reserve too low.
- Ext. TEACH-IN input

The desired contrast recognition capability can be adjusted by applying of a logic "high" pulse with a certain pulse lenght when the switch is in position T. Ŀ 50 ms (30 ms ... 100 ms)

- 11: 150 ms (100 ms ... 200 ms) > 200 ms
- 111: It is possible to change the contrast detection level without re-teaching. For contras detection mode (Teach-Mode) the stability reseve must be at least 2.5 (see curve "relative received light strength").



The Light-/Dark-Switch (Left, outer switch) is shown in the "Dark ON" position.



116657\_eng.xml

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" Pepperl+Fuchs Group www.pepperl-fuchs.com

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Туре	Description	Notes
-Z	one shot timer	Fixed time interval 0.02 s

## Additional information

#### Mounting instructions:

The sensor is held in place by two pass-through drill holes for M5. The surface underneath must be flat to prevent the housing from moving when it is tightened into position. We recommend securing the nuts in place with spring screws to prevent the sensor from going out of adjustment.

Outdoor mounting:

The sensors must be protected from shock and splashed water. It may be necessary to provide a covering.

#### Adjustment:

Align the unit to the reflector in the "N" switch setting. The yellow LED must be lit constantly. Move the switch to the "T" setting and wait for about 1 sec. until the yellow LED starts flashing slowly.

Move the switch to the setting for the desired contrast detection level: "I" for 10%, "II" for 18%, "III" for 40%.

or

In switch setting "T", select the appropriate contrast detection level by applying a pulse through the control lead to connection pin 5 (see "TEACH-IN").

#### **Contrast detection levels:**

The output becomes inactive if dirt and dust make it impossible to readjust the setting. In this case the yellow LED will flash quickly.

If dirt and dust continue to accumulate, detection of slight contrasts can no longer be guaranteed.

Δ

